

General Instructions:

The purpose of form TCEQ-20700 Backflow Prevention Assembly Test and Maintenance Report (T&M Form) is to document the results of testing a backflow prevention assembly. The form can be completed in one of two ways:

- 1. The form can be printed and completed by hand, or
- 2. The form can be completed electronically through an electronic medium (tablet, laptop computer, etc.). The yellow areas on the form can be completed electronically.

NOTE: <u>*The form is intended to be completed on-site while testing is occurring.*</u> If the form is completed electronically, the electronic device must also be on-site for proper use of this form.

The form must be printed and signed by the Licensed Tester that performed the work, unless TCEQ approved electronic recording keeping is in use. The hardcopy original must be provided to the Public Water System (PWS) as specified in *Title 30 of the Texas Administrative Code 290.44(h)(4)(c)*.

Specific Instructions:

Please follow the instructions below when completing form TCEQ-20700:

- 1. Check boxes: If completing the form electronically, all check boxes can be selected to make the desired indication. Selecting a box will insert an "X" in the box.
- 2. When performing the test, if the "Initial Test" yields acceptable results, do not complete the "Repairs and Materials Used**" or "Test After Repairs" rows on the form.
- 3. Remarks: If completing the form electronically, the "Remarks" section of the form is expandable, which means the final report can be more than one page. All pages of the T&M Report must be submitted to the water system.
- 4. Testing completed by a licensed tester must be documented on one form. Any follow-up testing performed by a different tester must be documented on a separate form.

Things to remember:

- 1. Differential pressure gauges:
 - a. In order to prevent contamination, gauges used on potable water backflow prevention assemblies must **not** be used to test non-potable backflow prevention assemblies.
 - b. Gauges need to be tested for accuracy annually and that date plus the serial number and other gauge information must be correctly recorded on the form. This allows Public water systems to ensure that the gauges are in compliance.
- 2. Annual testing of backflow prevention assemblies (those installed to protect against health hazards) or differential pressure gauges is to occur no more than 12 months from the last test date.
- 3. A tester's license is based on the testing procedures described in the University of Southern California's 10th edition manual. These procedures are expected to be used when testing backflow prevention assemblies.
- 4. Type II assemblies: This form can only accommodate a Type II assembly with a single check bypass.

Texas Commission on Environmental Quality BACKFLOW PREVENTION ASSEMBLY TEST AND MAINTENANCE REPORT

The following form must be completed for eac	ch assembly tested. A signed	d and dated original m	ust be submitted to the p	oublic water supplier	for recordkeeping *purposes:
NAME OF PWS:	Luella Special Utility District				
PWS ID#:	0910032				
PWS MAILING ADDRESS:					
PWS CONTACT PERSON:					
ADDRESS OF SERVICE:					
The backflow prevention assembl			l maintained as re	quired by comr	nission regulations
and is certified to be operating with			ON ASSEMBLY	/ (BPA)•	
TYPE OF BACKFLOW PREVENTION ASSEMBLY (BPA): Image: Reduced Pressure Principle (RPBA) Image: Reduced Pressure Principle-Detector (RPBA-D) Type II					
$\square \text{Double Check Valve (DCVA)} \square$		Double Check-Detector (DCVA-D) Type II			
Image: Second Pressure Vacuum Breaker (PVB) Image: Second Pressure Vacuum Breaker (SVB)					
Manufacturer: Main: Bypass: Size: Main: Bypass:					
	Main: Bypass:		BPA Location:		Dypass.
Serial Number: Main:	Bypass:	BPA Serves:			
Schartvanioer, hanning Diffusion Birriserves.					
Reason for test: New D Existing D Replacement D Old Model/Serial #					
Is the assembly installed in accordance with manufacturer recommendations and/or local codes?					
Is the assembly installed on a non	ly (auxiliary)?			Yes No	
TEST RESULT		Type II			
Reduced Pressur	re Principle Assemb	ly (RPBA)	Assembly	PVB & SVB	
PASS D	CVA				
	1 st Check 2 nd Check***		Bypass Check	Air Inlet	Check Valve
	[]				
· · · · · · · · · · · · · · · · ·	Held at psid	· · ·	·	Opened at	psid Held at
Date: Closed Tight	Closed Tight	Did not	Closed Tight \Box	· · · · · · · · · · · · · · · · · · ·	psid
	Leaked	open	Leaked	Did it fully open $(Y_{ab} \square \square)$	
				(Yes 🛛 /No 🗖	
Repairs and Main:					
Materials Used** Bypass:					
- J F		<u>п т т</u>	Г 1	r r	1 I I I
	, <u> </u>	·	······································	Opened at	psid Held at
	Closed Tight	-	Closed		psid
Date: Time:			Tight 🔲		
		and for DCVA	~~1~·		
*** 2 nd check: numeric reading required for DCVA only Differential pressure gauge used: Potable: Non-Potable:					
		Potable: Image: Non-Potable: Image: Date tested for accuracy :			
Make/Model:	SN:		Date tes	sted for accurac	y:
Remarks:					
Company Name:	Licensed Tester Name				
Company Address:		(Print/Type): Licensed Tester Name (Signature):			
Company Address		Licongod Tostan	Nomo (Cimotura		
Company Address:		Licensed Tester	Name (Signature):	
):	
Company Address: Company Phone #:		Licensed Tester BPAT License # License Expirati	ŧ):	

* TEST RECORDS MUST BE KEPT FOR AT LEAST THREE YEARS [30 TAC §290.46(B)]

** USE ONLY MANUFACTURER'S REPLACEMENT PARTS